



## *Declaration of Conformity*

Registration No: 290618.AFSDOC.01

**Issue Date: June 29, 2018**

# **SONOAFS-ALU SHINE ECOSOFT**

insulated flexible air duct  
was tested pursuant to applicable test procedures  
and complies with the requirements of

**EN 13180: 2001**

**TS EN 13180: 2006**

**Manufacturer** : **AFS BORU SANAYI A.S.**  
Ivedik O.S.B. 1468 Cad. No:153 Ostim 06370 Ankara / Turkey

**Diameter Range** :  $\varnothing$  102 mm –  $\varnothing$  305 mm

**Test Results** : Diameter class : B  
Air tightness class : C  
Positive rated pressure : 3000 Pa  
Negative rated pressure : - 150 Pa  
Minimum bending radius : 0.5 D  
Sag : 4° to 12°  
Crushing strength : compressed 12 to 15 kg. and uncompr. 1.0 to 1.4 kg.

Authorized by : \_\_\_\_\_

**Zahid Poyraz**  
General Coordinator