



DECLARATION OF PERFORMANCE



DOP-FD-07

- Unique identification code of the product-type:
FD fire damper (see table below for specific damper installation type)
To be used in conjunction with walls/partitions/floors to maintain fire compartments in heating, ventilating and air conditioning installations
- Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5) of the CPR (Regulation (EU) no 305/2011):
3. BSB Engineering Services Ltd,
Unit 56, Mill Way, Trinity Trade Centre, Sittingbourne, Kent, ME10, 2PD
- System or systems of assessment and verification of constancy of performance of the construction product as set out in the CPR, Annex V:
System 1
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
BRE Global Assurance (Ireland) Ltd (2831) performed the determination of the product type on the basis of type testing (including sampling), type calculation, tabulated values or descriptive documentation of the product, the initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the certificate of constancy of performance of the factory production control (no. CPR-P0006).
- Declared performance according to:
EN 15650 (Ventilation for Buildings – Fire Dampers)

Essential Characteristics				Performance
Fire resistance according to EN 1366-2 and classifications according to EN 13501-3:				
Range	Type	Supporting construction	Classification/EXAP reports	Classification (BS EN 13501-3)
100 x 100mm up to 1200 x 1000mm	FD-AF	Drywall Partition	287718A/2	E 120 (ve i ↔ o)
100 x 100mm up to 1200 x 1000mm	FD-AF	Masonry Wall	287718A/2	E 120 (ve i ↔ o)
Multiple arrangement (infinite unit qty)	FD-AF	Drywall Partition	P101872-1000-1	E 120 (ve i ↔ o)
Multiple arrangement (infinite unit qty)	FD-AF	Masonry Wall	P101872-1000-1	E 120 (ve i ↔ o)
100 x 100mm up to 1200 x 1000mm	FD-AF	Concrete Floor	287718B/2	E 120 (ho i → o)
100 x 100mm up to 1200 x 1000mm	FD-PF / FD-CL	Drywall Partition	287718C/1	E 120 (ve i → o)
100 x 100mm up to 1200 x 1000mm	FD-PF / FD-CL	Masonry Wall	287718C/1	E 120 (ve i → o)
100 x 100mm up to 1200 x 1000mm	FD-HF	Masonry Wall	274347/3	E 120 (ve i → o)
100 x 100mm up to 1200 x 1000mm	FD-HF	Concrete Floor	274347/3	E 120 (ho i → o)
Galvanised steel, 430 stl & 316 stl/stl blades and case options allowed via BRE/BSB EXAP report P101872-1000/1				
Circular / dampers from 100 mm dia up to 1000mm dia - all of the above classifications apply (except multiple).				
Nominal activation conditions/sensitivity according to ISO 10294-4: - sensing element load bearing capacity - sensing element response time				Pass Pass
Response delay (response time) according to EN 1366-2: - closure time				Pass
Operational reliability according to EN 1366-2: - cycling				Pass (50 cycles)
Durability of response delay according to ISO 10294-4: - sensing element response temperature and load bearing capacity				Pass

 Harmonised technical specification:
EN 15650:2010

Signed for and on behalf of BSB by:

Date: 21st April 2020

Mike Backham
Technical Director
BSB Engineering Services Ltd

